

DIVISION III
GENERAL CONSTRUCTION REQUIREMENTS

SECTION 34

PRESSURE PIPE RESTRAINT

34.1 GENERAL

Pressure pipe fittings and other items requiring restraint shall use restraining assemblies as specified in this Section. Where the construction of improvements are privately funded, the ENGINEER may select the use of either mechanically restrained joints or poured in-place concrete thrust blocks as specified below. All City funded improvements shall be installed using mechanically restrained joints.

It is recommended that for PVC pipe, twelve (12) inches and smaller, all restraining to prevent movement of lines under pressure at bends, tees, caps, valves, hydrants, etc., be accomplished using mechanically restrained joints as specified in Sections 34.3 and 34.4.

All pressure pipe and fittings larger than twelve (12) inches shall be restrained as specified in Sections 34.3 and 34.4. Use of thrust blocks for pressure pipe and fittings sixteen (16) inches and larger shall not be allowed.

Ductile iron pressure pipe and fittings twelve (12) inches and smaller may be restrained as established in Sections 34.3 and 34.4.

34.2 THRUST BLOCK CONSTRUCTION

Thrust blocks shall be constructed as shown on the DRAWINGS. Where undisturbed trench walls are not available for thrust blocking, the CONTRACTOR shall furnish additional concrete or install suitable pipe harnesses or ties designed and manufactured specifically for this purpose. Additional concrete, harnesses, and/or ties shall be approved by the ENGINEER and the CITY.

Fittings shall be protected by polyethylene film, minimum 8 mil thick, prior to placing concrete thrust block.

Concrete for thrust blocking shall have a minimum compressive strength of 3000 psi. Concrete shall be placed against undisturbed material, shall not cover joints, bolts, or nuts, or interfere with the removal of any joint. Wooden side forms shall be provided for thrust blocks where trench conditions require. Thrust blocks shall be properly set and adequately cured prior to pressurizing the system.

DIVISION III
GENERAL CONSTRUCTION REQUIREMENTS

34.3 RESTRAINED JOINT CONSTRUCTION

Restrained joint piping shall be constructed using pipe and fittings with restrained "Locked-type" joints compatible with the pipe. The joints shall be capable of holding against a minimum pressure of fifty (50) percent above the normal working pressure. Mechanical joint ductile iron pipe retainer glands shall be permitted upon specific written consent by the DIRECTOR. Any restrained joints that allow for elongation upon pressurization will not be allowed in those locations where the pipe comes out of the ground.

Restrained pipe joints that achieve restraint by incorporating cut out sections in the wall of the pipe shall have a minimum wall thickness at the point of cut out that corresponds with the minimum specified wall thickness for the rest of the pipe.

The minimum number of restrained joints required for resisting forces at fittings and changes in direction of pipe shall be determined from the length of restrained pipe on each side of fittings and changes in direction necessary to develop adequate resisting friction with the soil.

The required lengths of restrained joint ductile iron pipe shall be determined by the ENGINEER and shown in a tabular form as depicted on the "Restrained Pipe Table" in the STANDARD DRAWINGS. All calculation shall be based on the method outlined in the publication entitled "Ductile Iron Pipe and Fittings" (AWWA M41), latest edition, published by American Water Works Association.

Wherever 2-45° bends are used in place of a 90° bend and the minimum restrained joints required from one 45° bend extend beyond the other 45° bend, the 2-45° bends will be considered as though a 90° bend were located midway between the 2-45° bends.

34.4 MECHANICAL RESTRAINING DEVICES

34.4.1 GENERAL

CITY approved mechanical restraining devices, which are compatible with the ductile iron pipe in use, may be substituted for the restrained "Locked-Type" joints. The number of joints to be restrained shall be based on the "Restrained Pipe Table" in the STANDARD DRAWING.

DIVISION III
GENERAL CONSTRUCTION REQUIREMENTS

34. 4. 2 JOINT RESTRAINT DEVICE

Mechanical joint restraint shall be incorporated in the design of the follower gland and shall include a restraining mechanism which, when actuated, imparts multiple wedging action against the pipe, increasing its resistance as the pressure increases. Flexibility of the joint shall be maintained after burial. Glands shall be manufactured of ductile iron conforming to ASTM A-536.

Restraining devices shall be of ductile iron heat treated to a minimum hardness of 370 BHN. Dimensions of the gland shall be such that it can be used with the standardized mechanical joint bell and tee-head bolts conforming to ANSI A21.11 and ANSI/AWWA C153/A21.53. Twist-off nuts shall be used to insure proper actuating of the restraining devices.

The mechanical joint restraint device shall have a working pressure of at least 250psi with a minimum safety factor of 2:1.