

NOTES:

ETAIL

- DRIVEWAY AND APRON SHALL BE SIX (6) INCH THICK, 3000 P.S.I. CONCRETE
- ? POWER TO THE PUMP STATION SHALL BE THROUGH UNDERGROUND CONDUIT FROM SUPPLY SOURCE IN RIGHT OF WAY.
- Ņ LANDSCAPING SHALL BE REQUIRED AROUND PERIMETER OF FENCE
- 4. DEVELOPER SHALL INSTALL AN AUTOMATICALLY CONTROLLED AC POWERED SPRINKLER SYSTEM FOR LANDSCAPING. RECLAIMED WATER SHALL BE USED WHERE AVAILABLE
- 5. ENGINEER SHALL PROVIDE A SCALED (1" = 20' MIN.) SITE SPECIFIC DETAIL DRAWING ON FIGURE 302.
- რ THE DEVELOPER SHALL BE RESPONSIBLE FOR ALL UTILITY ACCOUNTS DURING CONSTRUCTION UNTIL PROJECT IS ACCEPTED BY THE CITY.

PUMP STATION TYPICAL SITE PLAN