



GENERAL NOTES:

- A. ALL UTILITY PIPES SHALL BE INSTALLED WITH 6 INCH WIDE VINYL CONTINUOUS NON-METALLIC TAPE, FOR IDENTIFICATION AND WARNING PURPOSES, BURIED ABOVE THE PIPE AT A MAXIMUM DEPTH OF 18 INCHES OR AS APPROVED BY THE CITY. IT SHALL BE COLOR CODED AND WORDED AS FOLLOWS:
- | | |
|---|---|
| <p>1. POTABLE WATER</p> <p>A. COLOR: BLUE WITH BLACK LETTERING.</p> <p>B. LETTERING: "CAUTION: WATER LINE BURIED BELOW" OR SIMILAR WORDING.</p> | <p>3. GRAVITY SEWER</p> <p>A. COLOR: GREEN WITH BLACK LETTERING.</p> <p>B. LETTERING: "CAUTION: SEWER LINE BURIED BELOW" OR SIMILAR WORDING.</p> |
| <p>2. RECLAIMED WATER</p> <p>A. COLOR: PURPLE WITH BLACK LETTERING.</p> <p>B. LETTERING: "CAUTION: RECLAIMED WATER LINE BURIED BELOW" OR SIMILAR WORDING.</p> | <p>4. SEWER FORCE MAIN</p> <p>A. COLOR: BROWN WITH BLACK LETTERING.</p> <p>B. LETTERING: "CAUTION: SEWER FORCE MAIN BURIED BELOW" OR SIMILAR WORDING.</p> |
- B. 10 GAUGE SOILD COPPER WIRE W/600V INSULATOR, CONTINUOUS COLOR SHALL BE INSTALLED ALONG ALL PRESSURIZED MAINS. USE PRE-FILLED DRI-SPLICE WIRE CONNECTORS W/CRIMP SLEEVE FOR ALL WIRE SPLICING, (SPEARS DE-400 or APPROVED EQUAL). THE WIRE SHALL BE LOOPED AND TIED TO ALL VALVE BOXES, (SEE FIG. 400).

UTILITY PIPE WARNING TAPE

(SEWER, POTABLE WATER, AND RECLAIMED WATER)